

	FIRST LETTER	(MODIFIER)	SECOND LETTER	THIRD LETTER	(MODIFIER)
A	Analysis		Alarm		
B	Burner Flame		User Choice	User Choice	User Choice
C	Conductivity			Control	
D	Density or S.G.	Differential			
E	Voltage		Primary Element		
F	Flow Rate	Ratio (Fraction)			
G	Gaging		Glass		
H	Hand				High
I	Current		Indicate		
J	Power	Scan			
K	Time			Control Station	
L	Level		Light (Pilot)		Low
M	Moisture (Humidity)				Middle (Intermediate
N	User Choice		User Choice	User Choice	User Choice
O	User Choice		Orifice (Restriction)		
P	Pressure (Vacuum)		Point (Test Connection)		
Q	Quantity (Event)	Integrate (Totalize)			
R	Radioactivity		Record (Print)		
S	Speed (Frequency)	Safety		Switch	
T	Temperature			Transmit	
U	Multivariable		Multifunction	Multifunction	Multifunction
V	Viscosity			Valve, Damper, Louver	
W	Weight (Force)		Well		
X	Unclassified		Unclassified	Unclassified	Unclassified
Y	User Choice			Relay (Compute)	
Z	Position			Drive, Actuate, Unclass Final Ctrl Ele	